



Final Report

Minnesota Department of Health
Public Health Laboratory
Environmental Laboratory Section
601 Robert St. N., P.O. Box 64899
St. Paul, MN 55164-0899
651-201-5300

PWSID: Child Care Resource & Referral HeadStart Rochester Program Code: HK
System Name: 804236
City: None

Type:

Date Received: 07/25/25 10:06 Collector Name: Facility Staff - Alison Fife
Rep. Temp. (°C): 23.9 Collector ID: None

MDH Sample Number: 25G2267-01

Location ID: 101
Sampling Point: 478997

Collect Date: 07/24/25
Collect Time: 06:27
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B5G1811	07/30/25 10:54	07/30/25 14:33	MDH-A	EPA 200.8	

MDH Sample Number: 25G2267-02

Location ID: 101A
Sampling Point: 478988

Collect Date: 07/24/25
Collect Time: 06:30
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B5G1811	07/30/25 10:54	07/30/25 14:34	MDH-A	EPA 200.8	

FINAL REPORT

Report ID: 08262025182451

Generated: 8/26/2025 6:24:49PM

Authorized by:

Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.

PWSID: Child Care Resource & Referral HeadStart Rochester

MDH Sample Number: 25G2267-03

Location ID: 102
Sampling Point: 478996

Collect Date: 07/24/25
Collect Time: 06:26
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B5G1811	07/30/25 10:54	07/30/25 14:34	MDH-A	EPA 200.8	

MDH Sample Number: 25G2267-04

Location ID: 103
Sampling Point: 478995

Collect Date: 07/24/25
Collect Time: 06:17
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B5G1811	07/30/25 10:54	07/30/25 14:35	MDH-A	EPA 200.8	

MDH Sample Number: 25G2267-05

Location ID: 104
Sampling Point: 478994

Collect Date: 07/24/25
Collect Time: 06:19
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters


Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B5G1811	07/30/25 10:54	07/30/25 14:38	MDH-A	EPA 200.8	

FINAL REPORT

Report ID: 08262025182451

Generated: 8/26/2025 6:24:49PM

Authorized by:



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.

PWSID: Child Care Resource & Referral HeadStart Rochester

MDH Sample Number: 25G2267-06

Location ID: 105
Sampling Point: 478993

Collect Date: 07/24/25
Collect Time: 06:21
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B5G1811	07/30/25 10:54	07/30/25 14:39	MDH-A	EPA 200.8	

MDH Sample Number: 25G2267-07

Location ID: 106
Sampling Point: 478992

Collect Date: 07/24/25
Collect Time: 06:13
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B5H1021	08/05/25 08:36	08/05/25 10:31	MDH-A	EPA 200.8	

MDH Sample Number: 25G2267-08

Location ID: 401
Sampling Point: 478991

Collect Date: 07/24/25
Collect Time: 06:33
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters


Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B5H1021	08/05/25 08:36	08/05/25 10:32	MDH-A	EPA 200.8	

FINAL REPORT

Report ID: 08262025182451

Generated: 8/26/2025 6:24:49PM

Authorized by:



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.



Final Report

Minnesota Department of Health
Public Health Laboratory
Environmental Laboratory Section
601 Robert St. N., P.O. Box 64899
St. Paul, MN 55164-0899
651-201-5300

PWSID: Child Care Resource & Referral HeadStart Rochester

MDH Sample Number: 25G2267-09

Location ID: 401A
Sampling Point: 478989

Collect Date: 07/24/25
Collect Time: 06:35
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B5H1021	08/05/25 08:36	08/05/25 10:33	MDH-A	EPA 200.8	

MDH Sample Number: 25G2267-10

Location ID: 402
Sampling Point: 478990

Collect Date: 07/24/25
Collect Time: 06:32
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B5H1021	08/05/25 08:36	08/05/25 10:35	MDH-A	EPA 200.8	

FINAL REPORT

Report ID: 08262025182451

Generated: 8/26/2025 6:24:49PM

Authorized by:

Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.

PWSID: Child Care Resource & Referral HeadStart Rochester

Results were produced by Minnesota Department of Health, except where noted.

Batch B5G1811 - EPA 200 Series Prep

Blank (B5G1811-BLK1)

Prepared: 07/30/25 10:54 Analyzed: 07/30/25 14:16

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	<	1.00	ug/L								MDH-A

LCS (B5G1811-BS1)

Prepared: 07/30/25 10:54 Analyzed: 07/30/25 14:16

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	50.5		ug/L	50		101	85-115				MDH-A

Duplicate (B5G1811-DUP1)

Source: 25G2104-02

Prepared: 07/30/25 10:54 Analyzed: 07/30/25 14:20

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	0.15	1.00	ug/L		<			2	20		MDH-A

Duplicate (B5G1811-DUP2)

Source: 25G2267-04

Prepared: 07/30/25 10:54 Analyzed: 07/30/25 14:36

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	<	1.00	ug/L		<				20		MDH-A

Matrix Spike (B5G1811-MS1)

Source: 25G2104-02

Prepared: 07/30/25 10:54 Analyzed: 07/30/25 14:21

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	47.8		ug/L	50		95	70-130				MDH-A

Matrix Spike (B5G1811-MS2)

Source: 25G2267-04

Prepared: 07/30/25 10:54 Analyzed: 07/30/25 14:37

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	47.0		ug/L	50		94	70-130				MDH-A

Batch B5H1021 - EPA 200 Series Prep

FINAL REPORT


Report ID: 08262025182451

Generated: 8/26/2025 6:24:49PM

Authorized by:

The results in this report apply only to the samples analyzed.

This report must not be reproduced, except in full, without the written approval of the laboratory.



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health



DEPARTMENT
OF HEALTH

Final Report

Minnesota Department of Health
Public Health Laboratory
Environmental Laboratory Section
601 Robert St. N., P.O. Box 64899
St. Paul, MN 55164-0899
651-201-5300

PWSID: Child Care Resource & Referral HeadStart Rochester

Results were produced by Minnesota Department of Health, except where noted.

Batch B5H1021 - EPA 200 Series Prep

Blank (B5H1021-BLK1)

Prepared: 08/05/25 08:36 Analyzed: 08/05/25 10:29

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	<	1.00	ug/L								MDH-A

LCS (B5H1021-BS1)

Prepared: 08/05/25 08:36 Analyzed: 08/05/25 10:30

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	50.2		ug/L	50		100	85-115				MDH-A

Duplicate (B5H1021-DUP1)

Source: 25G2267-09

Prepared: 08/05/25 08:36 Analyzed: 08/05/25 10:34

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	<	1.00	ug/L		<				20		MDH-A

Duplicate (B5H1021-DUP2)

Source: 25H0015-01

Prepared: 08/05/25 08:36 Analyzed: 08/05/25 10:50

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	2.17	1.00	ug/L		2.16			0.7	20		MDH-A

Matrix Spike (B5H1021-MS1)

Source: 25G2267-09

Prepared: 08/05/25 08:36 Analyzed: 08/05/25 10:35

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	46.7		ug/L	50		93	70-130				MDH-A

Matrix Spike (B5H1021-MS2)

Source: 25H0015-01

Prepared: 08/05/25 08:36 Analyzed: 08/05/25 10:51

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	49.8		ug/L	50		95	70-130				MDH-A

FINAL REPORT

Report ID: 08262025182451

Generated: 8/26/2025 6:24:49PM

Authorized by:

Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.

PWSID: Child Care Resource & Referral HeadStart Rochester

Work Order Comments

Samples were received in proper condition.

FINAL REPORT

Report ID: 08262025182451

Generated: 8/26/2025 6:24:49PM

Authorized by:

The results in this report apply only to the samples analyzed.

This report must not be reproduced, except in full, without the written approval of the laboratory.

Stefan Saravia

Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health



Final Report

Minnesota Department of Health
Public Health Laboratory
Environmental Laboratory Section
601 Robert St. N., P.O. Box 64899
St. Paul, MN 55164-0899
651-201-5300

PWSID: Child Care Resource & Referral HeadStart Rochester Program Code: HK
System Name: 804236
City: None

Type:

Date Received: 08/04/25 09:39 Collector Name: Facility Staff - Alison Fife
Rep. Temp. (°C): 23.1 Collector ID: None

MDH Sample Number: 25H0169-01

Location ID: 106
Sampling Point: 480358

Collect Date: 08/01/25
Collect Time: 06:13
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B5H1114	08/07/25 07:57	08/07/25 09:56	MDH-A	EPA 200.8	

FINAL REPORT

Report ID: 09032025145400

Generated: 9/3/2025 2:53:52PM

Authorized by:

The results in this report apply only to the samples analyzed.

This report must not be reproduced, except in full, without the written approval of the laboratory.

Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: Child Care Resource & Referral HeadStart Rochester

Results were produced by Minnesota Department of Health, except where noted.

Batch B5H1114 - EPA 200 Series Prep

Blank (B5H1114-BLK1)

Prepared: 08/07/25 07:57 Analyzed: 08/07/25 09:49

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	<	1.00	ug/L								MDH-A

LCS (B5H1114-BS1)

Prepared: 08/07/25 07:57 Analyzed: 08/07/25 09:50

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	48.7		ug/L	50		97	85-115				MDH-A

Duplicate (B5H1114-DUP1)

Source: 25H0441-01

Prepared: 08/07/25 07:57 Analyzed: 08/07/25 09:59

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	4.73	1.00	ug/L		4.74			0.1	20		MDH-A

Matrix Spike (B5H1114-MS1)

Source: 25H0441-01

Prepared: 08/07/25 07:57 Analyzed: 08/07/25 09:59

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	50.4		ug/L	50		91	70-130				MDH-A

Work Order Comments

Samples were received in proper condition.

FINAL REPORT

Report ID: 09032025145400

Generated: 9/3/2025 2:53:52PM

Authorized by:

The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health